

# Legally Required Evidence of Conformity

## Construction Products Regulation Declaration of Performance

### Required Information for New Fire Resisting Shutters

Responsible company details  
Notified bodies used and their reference numbers.

Intended use and product ID.

1 - 8 characteristics and performances tested by the notified test laboratory.

9 & 10 characteristics and performances tested by the responsible company.

11 - 16 characteristics and performances tested by the notified test laboratory and certified by the notified product certification body.

Responsible company declaration.

Construction Products Regulation Declaration of Performance (EU) 305 2011			
XYZ Industrial Doors Ltd, Unit 10 industrial estate, Anytown, AN1 2TN			
System 3 testing by XPT test labs 1234			
System 1 certification by NPCB 5678			
Fire resisting shutter XYZ 1234			
Essential Characteristics	Declared Performance	AVCP System	Harmonised Standards
1. Water tightness	NPD	3	EN 13241: 2003 + A2:2016
2. Air permeability	NPD	3	
3. Thermal resistance	NPD	3	
4. Durability of 1 - 3	NPD	3	
5. Operating forces	PASS	3	
6. Safe opening	PASS	3	
7. Resistance to wind load	4	3	
8. Dangerous substances	NONE	3	
9. Glazing	NONE	4	
10. Mechanical resistance and stability	PASS	4	
11. Resistance to fire	E I <sub>1</sub> I <sub>2</sub> W	240 NPD NPD NPD	EN 16034:2014
12. Smoke control	NPD	1	
13. Ability to release	RELEASED	1	
14. Self-closing	C	1	
15. Durability of self-closing against degradation and ageing	5,000	1	
16. Durability of ability to release	NPD	1	
The performance of the product identified above is in conformity with the declared performances. This declaration of performance is issued under the sole responsibility of the manufacturer identified above.			
Date: 01 November 2019 <i>Steve Smith</i> Compliance Manager			

Applicable harmonised standards and AVCP systems.


Note 1 - the reference to operating force will be NPD for manual shutters.

Note 2 - powered doors should also have a Machinery Directive Declaration of Conformity issued.

# Legally Required Evidence of Conformity

## CPR & MD CE Plate

### Required Information for New Fire Resisting Shutters

Responsible company details.	XYZ Industrial Doors Ltd, Unit 10 industrial estate, Anytown, AN1 2TN			
CE and references to applicable directives and regulations.		(EU) 305/2011 & 2006/42/EC	20	Year of manufacture
			Fire resisting shutter	Intended use
			Model: XYZ 1234	Model identification
Characteristics and performances as per the DOP	Essential Characteristics		Declared Performance	Harmonised Standards
	Operating forces		PASS	EN 13241:2003 + A2:2016
	Safe opening		PASS	
	Resistance to wind load		4	
	Dangerous substances		NONE	
	Mechanical resistance and stability		PASS	EN 16034:2014
	Resistance to fire		E240	
	Ability to release		RELEASED	
	Self-closing		C	
	Durability of self-closing against degradation and ageing		5000	
Notified bodies used and their reference no.	System 3 testing by XPT test labs 1234 System 1 testing & certification by NPCB 5678			Applicable harmonised standards

Note 1 - the references to 2006/42/EC (Machinery Directive) and operating force are only required for powered doors